



alpha

Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

24 June 2019

Paradise Unified School District

Attn: Jacob Timm

6696 Clark Rd.

Paradise, CA 95969

RE: 2-Fire RemediationMonitoring

Work Order: 19F1097

Enclosed are the results of analyses for samples received by the laboratory on 06/10/19 22:08. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Chelsea L. Sandelin For Rachel J. Kaua

Project Manager



Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District
6696 Clark Rd.
Paradise, CA 95969

Project Manager: Jacob Timm
Project: 2-Fire RemediationMonitoring
Project Number: [none]

Reported:
06/24/19 16:05

Bay Area: 262 Rickenbacker Circle | Livermore, CA 94551 | T: 925-828-6226 | F: 925-828-6309 | ELAP# 2728
Central Valley: 9090 Union Park Way Suite 113 | Elk Grove, CA 95624 | T: 916-686-5190 | F: 916-686-5192 | ELAP# 2922
North Bay: 110 Liberty Street | Petaluma, CA 94952 | T: 707-769-3128 | F: 707-769-8093 | ELAP# 2303
San Diego Service Center: 2722 Loker Avenue West Suite A | Carlsbad, CA 92010 | T: 760-930-2555 | F: 760-930-2510

ANALYTICAL REPORT FOR SAMPLES

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
PHS Room 116	19F1097-01	Water	06/05/19 09:32	06/10/19 22:08
Drinking Fountain 123 PHS	19F1097-02	Water	06/05/19 09:43	06/10/19 22:08
PHS Room 125	19F1097-03	Water	06/05/19 09:48	06/10/19 22:08
PHS Health Office	19F1097-04	Water	06/05/19 10:06	06/10/19 22:08
200 Wing D.F. PHS	19F1097-05	Water	06/05/19 10:10	06/10/19 22:08
Cafe East D.F. PHS	19F1097-06	Water	06/05/19 10:42	06/10/19 22:08
PHS Kithchen	19F1097-07	Water	06/05/19 10:50	06/10/19 22:08
PHS 501	19F1097-08	Water	06/05/19 11:13	06/10/19 22:08
PHS Gym North D.F.	19F1097-09	Water	06/05/19 11:38	06/10/19 22:08
PHS Field House D.F.	19F1097-10	Water	06/05/19 11:52	06/10/19 22:08
PINT Cafe D.F.	19F1097-11	Water	06/05/19 13:50	06/10/19 22:08
PINT 200 West D.F.	19F1097-12	Water	06/05/19 13:37	06/10/19 22:08
PINT Health Office	19F1097-13	Water	06/05/19 13:42	06/10/19 22:08
PINT Kitchen	19F1097-14	Water	06/05/19 13:57	06/10/19 22:08
PINT 107	19F1097-15	Water	06/05/19 14:10	06/10/19 22:08
PINT 301	19F1097-16	Water	06/05/19 13:19	06/10/19 22:08
PINT Gym Girls L.R	19F1097-17	Water	06/05/19 14:08	06/10/19 22:08
PINT Gym E. D.F.	19F1097-18	Water	06/05/19 14:29	06/10/19 22:08
PINT 303	19F1097-19	Water	06/05/19 13:08	06/10/19 22:08
CENT Kitchen	19F1097-20	Water	06/05/19 08:41	06/10/19 22:08
D.O. North Kitchen	19F1097-21	Water	06/05/19 07:16	06/10/19 22:08
Bus Shed	19F1097-22	Water	06/05/19 08:31	06/10/19 22:08
D.O. Foyer D.F.	19F1097-23	Water	06/05/19 07:23	06/10/19 22:08
N. Staff Restroom D.O.	19F1097-24	Water	06/05/19 07:41	06/10/19 22:08

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District
6696 Clark Rd.
Paradise, CA 95969

Project Manager: Jacob Timm
Project: 2-Fire RemediationMonitoring
Project Number: [none]

Reported:
06/24/19 16:05

100 Wing W. D.F. PINT	19F1097-25	Water	06/05/19 14:18	06/10/19 22:08
Trip Blank	19F1097-26	Water	06/05/19 00:00	06/10/19 22:08



Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District
6696 Clark Rd.
Paradise, CA 95969

Project Manager: Jacob Timm
Project: 2-Fire RemediationMonitoring
Project Number: [none]

Reported:
06/24/19 16:05

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note	
PHS Room 116 (19F1097-01)		Sample Type: Water			Sampled: 06/05/19 09:32				
Volatile Organic Compounds by EPA Method 524.2									
Benzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
Carbon tetrachloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
Chlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
1,1-Dichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
1,2-Dichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
1,1-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
1,2-Dichloropropane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
Ethylbenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
Methylene chloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
Styrene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
Tetrachloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
Toluene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
Trichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
Trichlorofluoromethane	ND ug/L	5.0	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
Trichlorotrifluoroethane	ND ug/L	10	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
Vinyl chloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
Xylenes (total)	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
Surrogate: Bromofluorobenzene	104 %	70-130		AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
Surrogate: Dibromofluoromethane	85.3 %	70-130		AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
Surrogate: Toluene-d8	105 %	70-130		AF93568	06/13/19 13:00	06/13/19 17:08	EPA 524.2		
Drinking Fountain 123 PHS (19F1097-02)		Sample Type: Water			Sampled: 06/05/19 09:43				
Volatile Organic Compounds by EPA Method 524.2									
Benzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2		
Carbon tetrachloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2		
Chlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2		
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2		
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2		
1,1-Dichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2		
1,2-Dichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2		
1,1-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2		
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2		

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District
6696 Clark Rd.
Paradise, CA 95969

Project Manager: Jacob Timm
Project: 2-Fire RemediationMonitoring
Project Number: [none]

Reported:
06/24/19 16:05

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note
Drinking Fountain 123 PHS (19F1097-02)			Sample Type: Water			Sampled: 06/05/19 09:43		
Volatile Organic Compounds by EPA Method 524.2 (cont'd)								
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2	
1,2-Dichloropropane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2	
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2	
Ethylbenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2	
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2	
Methylene chloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2	
Styrene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2	
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2	
Tetrachloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2	
Toluene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2	
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2	
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2	
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2	
Trichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2	
Trichlorofluoromethane	ND ug/L	5.0	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2	
Trichlorotrifluoroethane	ND ug/L	10	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2	
Vinyl chloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2	
Xylenes (total)	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2	
Surrogate: Bromofluorobenzene	104 %	70-130		AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2	
Surrogate: Dibromofluoromethane	85.9 %	70-130		AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2	
Surrogate: Toluene-d8	105 %	70-130		AF93568	06/13/19 13:00	06/13/19 17:44	EPA 524.2	
PHS Room 125 (19F1097-03)			Sample Type: Water			Sampled: 06/05/19 09:48		
Volatile Organic Compounds by EPA Method 524.2								
Benzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2	
Carbon tetrachloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2	
Chlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2	
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2	
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2	
1,1-Dichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2	
1,2-Dichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2	
1,1-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2	
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2	
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2	
1,2-Dichloropropane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2	
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2	
Ethylbenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2	
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2	
Methylene chloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2	
Styrene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2	
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2	
Tetrachloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District
6696 Clark Rd.
Paradise, CA 95969

Project Manager: Jacob Timm
Project: 2-Fire RemediationMonitoring
Project Number: [none]

Reported:
06/24/19 16:05

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note	
PHS Room 125 (19F1097-03)		Sample Type: Water			Sampled: 06/05/19 09:48				
Volatile Organic Compounds by EPA Method 524.2 (cont'd)									
Toluene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2		
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2		
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2		
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2		
Trichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2		
Trichlorofluoromethane	ND ug/L	5.0	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2		
Trichlorotrifluoroethane	ND ug/L	10	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2		
Vinyl chloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2		
Xylenes (total)	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2		
Surrogate: Bromofluorobenzene	103 %	70-130		AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2		
Surrogate: Dibromofluoromethane	87.1 %	70-130		AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2		
Surrogate: Toluene-d8	106 %	70-130		AF93568	06/13/19 13:00	06/13/19 18:19	EPA 524.2		
PHS Health Office (19F1097-04)		Sample Type: Water			Sampled: 06/05/19 10:06				
Volatile Organic Compounds by EPA Method 524.2									
Benzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
Carbon tetrachloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
Chlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
1,1-Dichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
1,2-Dichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
1,1-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
1,2-Dichloropropane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
Ethylbenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
Methylene chloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
Styrene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
Tetrachloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
Toluene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
Trichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
Trichlorofluoromethane	ND ug/L	5.0	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
Trichlorotrifluoroethane	ND ug/L	10	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
Vinyl chloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		
Xylenes (total)	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2		

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District
6696 Clark Rd.
Paradise, CA 95969

Project Manager: Jacob Timm
Project: 2-Fire RemediationMonitoring
Project Number: [none]

Reported:
06/24/19 16:05

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note
PHS Health Office (19F1097-04)		Sample Type: Water			Sampled: 06/05/19 10:06			
Volatile Organic Compounds by EPA Method 524.2 (cont'd)								
Surrogate: Bromofluorobenzene	96.0 %	70-130		AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2	
Surrogate: Dibromofluoromethane	80.1 %	70-130		AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2	
Surrogate: Toluene-d8	101 %	70-130		AF93568	06/13/19 13:00	06/13/19 18:54	EPA 524.2	
200 Wing D.F. PHS (19F1097-05)		Sample Type: Water			Sampled: 06/05/19 10:10			
Volatile Organic Compounds by EPA Method 524.2								
Benzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
Carbon tetrachloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
Chlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
1,1-Dichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
1,2-Dichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
1,1-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
1,2-Dichloropropane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
Ethylbenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
Methylene chloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
Styrene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
Tetrachloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
Toluene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
Trichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
Trichlorofluoromethane	ND ug/L	5.0	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
Trichlorotrifluoroethane	ND ug/L	10	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
Vinyl chloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
Xylenes (total)	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
Surrogate: Bromofluorobenzene	103 %	70-130		AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
Surrogate: Dibromofluoromethane	86.7 %	70-130		AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
Surrogate: Toluene-d8	106 %	70-130		AF93568	06/13/19 13:00	06/13/19 19:28	EPA 524.2	
Cafe East D.F. PHS (19F1097-06)		Sample Type: Water			Sampled: 06/05/19 10:42			
Volatile Organic Compounds by EPA Method 524.2								
Benzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
Carbon tetrachloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
Chlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District
6696 Clark Rd.
Paradise, CA 95969

Project Manager: Jacob Timm
Project: 2-Fire RemediationMonitoring
Project Number: [none]

Reported:
06/24/19 16:05

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note
Cafe East D.F. PHS (19F1097-06)			Sample Type: Water			Sampled: 06/05/19 10:42		
Volatile Organic Compounds by EPA Method 524.2 (cont'd)								
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
1,1-Dichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
1,2-Dichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
1,1-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
1,2-Dichloropropane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
Ethylbenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
Methylene chloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
Styrene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
Tetrachloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
Toluene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
Trichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
Trichlorofluoromethane	ND ug/L	5.0	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
Trichlorotrifluoroethane	ND ug/L	10	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
Vinyl chloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
Xylenes (total)	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
Surrogate: Bromofluorobenzene	101 %	70-130		AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
Surrogate: Dibromofluoromethane	86.4 %	70-130		AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
Surrogate: Toluene-d8	105 %	70-130		AF93568	06/13/19 13:00	06/13/19 20:03	EPA 524.2	
PHS Kithchen (19F1097-07)			Sample Type: Water			Sampled: 06/05/19 10:50		
Volatile Organic Compounds by EPA Method 524.2								
Benzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2	
Carbon tetrachloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2	
Chlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2	
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2	
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2	
1,1-Dichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2	
1,2-Dichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2	
1,1-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2	
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2	
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2	
1,2-Dichloropropane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2	
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2	
Ethylbenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District
6696 Clark Rd.
Paradise, CA 95969

Project Manager: Jacob Timm
Project: 2-Fire RemediationMonitoring
Project Number: [none]

Reported:
06/24/19 16:05

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note	
PHS Kithchen (19F1097-07)		Sample Type: Water			Sampled: 06/05/19 10:50				
Volatile Organic Compounds by EPA Method 524.2 (cont'd)									
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2		
Methylene chloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2		
Styrene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2		
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2		
Tetrachloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2		
Toluene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2		
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2		
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2		
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2		
Trichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2		
Trichlorofluoromethane	ND ug/L	5.0	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2		
Trichlorotrifluoroethane	ND ug/L	10	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2		
Vinyl chloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2		
Xylenes (total)	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2		
Surrogate: Bromofluorobenzene	105 %	70-130		AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2		
Surrogate: Dibromofluoromethane	88.2 %	70-130		AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2		
Surrogate: Toluene-d8	107 %	70-130		AF93568	06/13/19 13:00	06/13/19 20:38	EPA 524.2		
PHS 501 (19F1097-08)		Sample Type: Water			Sampled: 06/05/19 11:13				
Volatile Organic Compounds by EPA Method 524.2									
Benzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
Carbon tetrachloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
Chlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
1,1-Dichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
1,2-Dichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
1,1-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
1,2-Dichloropropane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
Ethylbenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
Methylene chloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
Styrene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
Tetrachloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
Toluene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District
6696 Clark Rd.
Paradise, CA 95969

Project Manager: Jacob Timm
Project: 2-Fire Remediation Monitoring
Project Number: [none]

Reported:
06/24/19 16:05

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note	
PHS 501 (19F1097-08)		Sample Type: Water			Sampled: 06/05/19 11:13				
Volatile Organic Compounds by EPA Method 524.2 (cont'd)									
Trichloroethene	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
Trichlorofluoromethane	ND ug/L	5.0	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
Trichlorotrifluoroethane	ND ug/L	10	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
Vinyl chloride	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
Xylenes (total)	ND ug/L	0.50	1	AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
Surrogate: Bromofluorobenzene	100 %	70-130		AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
Surrogate: Dibromofluoromethane	89.3 %	70-130		AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
Surrogate: Toluene-d8	105 %	70-130		AF93568	06/13/19 13:00	06/13/19 21:13	EPA 524.2		
PHS Gym North D.F. (19F1097-09)		Sample Type: Water			Sampled: 06/05/19 11:38				
Volatile Organic Compounds by EPA Method 524.2									
Benzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
Carbon tetrachloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
Chlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
1,1-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
1,2-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
1,1-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
1,2-Dichloropropane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
Ethylbenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
Methylene chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
Styrene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
Tetrachloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
Toluene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
Trichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
Trichlorofluoromethane	ND ug/L	5.0	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
Trichlorotrifluoroethane	ND ug/L	10	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
Vinyl chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
Xylenes (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
Surrogate: Bromofluorobenzene	111 %	70-130		AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
Surrogate: Dibromofluoromethane	101 %	70-130		AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
Surrogate: Toluene-d8	107 %	70-130		AF93648	06/14/19 11:30	06/14/19 13:14	EPA 524.2		
PHS Field House D.F. (19F1097-10)		Sample Type: Water			Sampled: 06/05/19 11:52				

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District
6696 Clark Rd.
Paradise, CA 95969

Project Manager: Jacob Timm
Project: 2-Fire RemediationMonitoring
Project Number: [none]

Reported:
06/24/19 16:05

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note	
PHS Field House D.F. (19F1097-10)		Sample Type: Water			Sampled: 06/05/19 11:52				
Volatile Organic Compounds by EPA Method 524.2									
Benzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
Carbon tetrachloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
Chlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
1,1-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
1,2-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
1,1-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
1,2-Dichloropropane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
Ethylbenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
Methylene chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
Styrene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
Tetrachloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
Toluene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
Trichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
Trichlorofluoromethane	ND ug/L	5.0	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
Trichlorotrifluoroethane	ND ug/L	10	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
Vinyl chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
Xylenes (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
Surrogate: Bromofluorobenzene	110 %	70-130		AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
Surrogate: Dibromofluoromethane	99.6 %	70-130		AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
Surrogate: Toluene-d8	105 %	70-130		AF93648	06/14/19 11:30	06/14/19 13:48	EPA 524.2		
PINT Cafe D.F. (19F1097-11)		Sample Type: Water			Sampled: 06/05/19 13:50				
Volatile Organic Compounds by EPA Method 524.2									
Benzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
Carbon tetrachloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
Chlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
1,1-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
1,2-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
1,1-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District
6696 Clark Rd.
Paradise, CA 95969

Project Manager: Jacob Timm
Project: 2-Fire RemediationMonitoring
Project Number: [none]

Reported:
06/24/19 16:05

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note	
PINT Cafe D.F. (19F1097-11)		Sample Type: Water			Sampled: 06/05/19 13:50				
Volatile Organic Compounds by EPA Method 524.2 (cont'd)									
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
1,2-Dichloropropane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
Ethylbenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
Methylene chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
Styrene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
Tetrachloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
Toluene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
Trichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
Trichlorofluoromethane	ND ug/L	5.0	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
Trichlorotrifluoroethane	ND ug/L	10	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
Vinyl chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
Xylenes (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
Surrogate: Bromofluorobenzene	110 %	70-130		AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
Surrogate: Dibromofluoromethane	101 %	70-130		AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
Surrogate: Toluene-d8	107 %	70-130		AF93648	06/14/19 11:30	06/14/19 14:22	EPA 524.2		
PINT 200 West D.F. (19F1097-12)		Sample Type: Water			Sampled: 06/05/19 13:37				
Volatile Organic Compounds by EPA Method 524.2									
Benzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
Carbon tetrachloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
Chlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
1,1-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
1,2-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
1,1-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
1,2-Dichloropropane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
Ethylbenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
Methylene chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
Styrene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
Tetrachloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District
6696 Clark Rd.
Paradise, CA 95969

Project Manager: Jacob Timm
Project: 2-Fire RemediationMonitoring
Project Number: [none]

Reported:
06/24/19 16:05

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note	
PINT 200 West D.F. (19F1097-12)		Sample Type: Water			Sampled: 06/05/19 13:37				
Volatile Organic Compounds by EPA Method 524.2 (cont'd)									
Toluene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
Trichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
Trichlorofluoromethane	ND ug/L	5.0	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
Trichlorotrifluoroethane	ND ug/L	10	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
Vinyl chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
Xylenes (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
Surrogate: Bromofluorobenzene	110 %	70-130		AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
Surrogate: Dibromofluoromethane	99.2 %	70-130		AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
Surrogate: Toluene-d8	105 %	70-130		AF93648	06/14/19 11:30	06/14/19 14:56	EPA 524.2		
PINT Health Office (19F1097-13)		Sample Type: Water			Sampled: 06/05/19 13:42				
Volatile Organic Compounds by EPA Method 524.2									
Benzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
Carbon tetrachloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
Chlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
1,1-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
1,2-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
1,1-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
1,2-Dichloropropane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
Ethylbenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
Methylene chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
Styrene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
Tetrachloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
Toluene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
Trichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
Trichlorofluoromethane	ND ug/L	5.0	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
Trichlorotrifluoroethane	ND ug/L	10	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
Vinyl chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		
Xylenes (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2		

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District
6696 Clark Rd.
Paradise, CA 95969

Project Manager: Jacob Timm
Project: 2-Fire Remediation Monitoring
Project Number: [none]

Reported:
06/24/19 16:05

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note
PINT Health Office (19F1097-13)		Sample Type: Water			Sampled: 06/05/19 13:42			
Volatile Organic Compounds by EPA Method 524.2 (cont'd)								
Surrogate: Bromofluorobenzene	110 %	70-130		AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2	
Surrogate: Dibromofluoromethane	99.1 %	70-130		AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2	
Surrogate: Toluene-d8	107 %	70-130		AF93648	06/14/19 11:30	06/14/19 15:30	EPA 524.2	
PINT Kitchen (19F1097-14)		Sample Type: Water			Sampled: 06/05/19 13:57			
Volatile Organic Compounds by EPA Method 524.2								
Benzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
Carbon tetrachloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
Chlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
1,1-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
1,2-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
1,1-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
1,2-Dichloropropane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
Ethylbenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
Methylene chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
Styrene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
Tetrachloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
Toluene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
Trichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
Trichlorofluoromethane	ND ug/L	5.0	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
Trichlorotrifluoroethane	ND ug/L	10	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
Vinyl chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
Xylenes (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
Surrogate: Bromofluorobenzene	107 %	70-130		AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
Surrogate: Dibromofluoromethane	98.4 %	70-130		AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
Surrogate: Toluene-d8	104 %	70-130		AF93648	06/14/19 11:30	06/14/19 16:04	EPA 524.2	
PINT 107 (19F1097-15)		Sample Type: Water			Sampled: 06/05/19 14:10			
Volatile Organic Compounds by EPA Method 524.2								
Benzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2	
Carbon tetrachloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2	
Chlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2	
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District
6696 Clark Rd.
Paradise, CA 95969

Project Manager: Jacob Timm
Project: 2-Fire Remediation Monitoring
Project Number: [none]

Reported:
06/24/19 16:05

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note	
PINT 107 (19F1097-15)		Sample Type: Water			Sampled: 06/05/19 14:10				
Volatile Organic Compounds by EPA Method 524.2 (cont'd)									
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
1,1-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
1,2-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
1,1-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
1,2-Dichloropropane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
Ethylbenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
Methylene chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
Styrene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
Tetrachloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
Toluene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
Trichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
Trichlorofluoromethane	ND ug/L	5.0	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
Trichlorotrifluoroethane	ND ug/L	10	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
Vinyl chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
Xylenes (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
Surrogate: Bromofluorobenzene	108 %	70-130		AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
Surrogate: Dibromofluoromethane	98.6 %	70-130		AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
Surrogate: Toluene-d8	104 %	70-130		AF93648	06/14/19 11:30	06/14/19 16:38	EPA 524.2		
PINT 301 (19F1097-16)		Sample Type: Water			Sampled: 06/05/19 13:19				
Volatile Organic Compounds by EPA Method 524.2									
Benzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
Carbon tetrachloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
Chlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
1,1-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
1,2-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
1,1-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
1,2-Dichloropropane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
Ethylbenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District
6696 Clark Rd.
Paradise, CA 95969

Project Manager: Jacob Timm
Project: 2-Fire RemediationMonitoring
Project Number: [none]

Reported:
06/24/19 16:05

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note	
PINT 301 (19F1097-16)		Sample Type: Water			Sampled: 06/05/19 13:19				
Volatile Organic Compounds by EPA Method 524.2 (cont'd)									
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
Methylene chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
Styrene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
Tetrachloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
Toluene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
Trichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
Trichlorofluoromethane	ND ug/L	5.0	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
Trichlorotrifluoroethane	ND ug/L	10	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
Vinyl chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
Xylenes (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
Surrogate: Bromofluorobenzene	109 %	70-130		AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
Surrogate: Dibromofluoromethane	101 %	70-130		AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
Surrogate: Toluene-d8	107 %	70-130		AF93648	06/14/19 11:30	06/14/19 17:12	EPA 524.2		
PINT Gym Girls L.R (19F1097-17)		Sample Type: Water			Sampled: 06/05/19 14:08				
Volatile Organic Compounds by EPA Method 524.2									
Benzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
Carbon tetrachloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
Chlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
1,1-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
1,2-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
1,1-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
1,2-Dichloropropane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
Ethylbenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
Methylene chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
Styrene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
Tetrachloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
Toluene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
 Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District 6696 Clark Rd. Paradise, CA 95969	Project Manager: Jacob Timm Project: 2-Fire RemediationMonitoring Project Number: [none]	Reported: 06/24/19 16:05
--	--	-----------------------------

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note	
PINT Gym Girls L.R (19F1097-17)		Sample Type: Water			Sampled: 06/05/19 14:08				
Volatile Organic Compounds by EPA Method 524.2 (cont'd)									
Trichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
Trichlorofluoromethane	ND ug/L	5.0	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
Trichlorotrifluoroethane	ND ug/L	10	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
Vinyl chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
Xylenes (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
Surrogate: Bromofluorobenzene	109 %	70-130		AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
Surrogate: Dibromofluoromethane	102 %	70-130		AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
Surrogate: Toluene-d8	106 %	70-130		AF93648	06/14/19 11:30	06/14/19 17:45	EPA 524.2		
PINT Gym E. D.F. (19F1097-18)		Sample Type: Water			Sampled: 06/05/19 14:29				
Volatile Organic Compounds by EPA Method 524.2									
Benzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
Carbon tetrachloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
Chlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
1,1-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
1,2-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
1,1-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
1,2-Dichloropropane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
Ethylbenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
Methylene chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
Styrene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
Tetrachloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
Toluene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
Trichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
Trichlorofluoromethane	ND ug/L	5.0	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
Trichlorotrifluoroethane	ND ug/L	10	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
Vinyl chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
Xylenes (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
Surrogate: Bromofluorobenzene	110 %	70-130		AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
Surrogate: Dibromofluoromethane	104 %	70-130		AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
Surrogate: Toluene-d8	104 %	70-130		AF93648	06/14/19 11:30	06/14/19 18:19	EPA 524.2		
PINT 303 (19F1097-19)		Sample Type: Water			Sampled: 06/05/19 13:08				

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District
6696 Clark Rd.
Paradise, CA 95969

Project Manager: Jacob Timm
Project: 2-Fire RemediationMonitoring
Project Number: [none]

Reported:
06/24/19 16:05

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note
PINT 303 (19F1097-19)		Sample Type: Water			Sampled: 06/05/19 13:08			
Volatile Organic Compounds by EPA Method 524.2								
Benzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
Carbon tetrachloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
Chlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
1,1-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
1,2-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
1,1-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
1,2-Dichloropropane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
Ethylbenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
Methylene chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
Styrene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
Tetrachloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
Toluene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
Trichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
Trichlorofluoromethane	ND ug/L	5.0	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
Trichlorotrifluoroethane	ND ug/L	10	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
Vinyl chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
Xylenes (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
Surrogate: Bromofluorobenzene	112 %	70-130		AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
Surrogate: Dibromofluoromethane	101 %	70-130		AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
Surrogate: Toluene-d8	107 %	70-130		AF93648	06/14/19 11:30	06/14/19 18:53	EPA 524.2	
CENT Kitchen (19F1097-20)		Sample Type: Water			Sampled: 06/05/19 08:41			
Volatile Organic Compounds by EPA Method 524.2								
Benzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2	
Carbon tetrachloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2	
Chlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2	
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2	
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2	
1,1-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2	
1,2-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2	
1,1-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2	
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District
6696 Clark Rd.
Paradise, CA 95969

Project Manager: Jacob Timm
Project: 2-Fire RemediationMonitoring
Project Number: [none]

Reported:
06/24/19 16:05

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note	
CENT Kitchen (19F1097-20)		Sample Type: Water			Sampled: 06/05/19 08:41				
Volatile Organic Compounds by EPA Method 524.2 (cont'd)									
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2		
1,2-Dichloropropane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2		
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2		
Ethylbenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2		
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2		
Methylene chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2		
Styrene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2		
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2		
Tetrachloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2		
Toluene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2		
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2		
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2		
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2		
Trichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2		
Trichlorofluoromethane	ND ug/L	5.0	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2		
Trichlorotrifluoroethane	ND ug/L	10	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2		
Vinyl chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2		
Xylenes (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2		
Surrogate: Bromofluorobenzene	110 %	70-130		AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2		
Surrogate: Dibromofluoromethane	102 %	70-130		AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2		
Surrogate: Toluene-d8	104 %	70-130		AF93648	06/14/19 11:30	06/14/19 19:27	EPA 524.2		
D.O. North Kitchen (19F1097-21)		Sample Type: Water			Sampled: 06/05/19 07:16				
Volatile Organic Compounds by EPA Method 524.2									
Benzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2		
Carbon tetrachloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2		
Chlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2		
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2		
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2		
1,1-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2		
1,2-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2		
1,1-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2		
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2		
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2		
1,2-Dichloropropane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2		
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2		
Ethylbenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2		
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2		
Methylene chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2		
Styrene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2		
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2		
Tetrachloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2		

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District
6696 Clark Rd.
Paradise, CA 95969

Project Manager: Jacob Timm
Project: 2-Fire Remediation Monitoring
Project Number: [none]

Reported:
06/24/19 16:05

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note
D.O. North Kitchen (19F1097-21)		Sample Type: Water			Sampled: 06/05/19 07:16			
Volatile Organic Compounds by EPA Method 524.2 (cont'd)								
Toluene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2	
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2	
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2	
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2	
Trichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2	
Trichlorofluoromethane	ND ug/L	5.0	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2	
Trichlorotrifluoroethane	ND ug/L	10	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2	
Vinyl chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2	
Xylenes (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2	
Surrogate: Bromofluorobenzene	111 %	70-130		AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2	
Surrogate: Dibromofluoromethane	104 %	70-130		AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2	
Surrogate: Toluene-d8	106 %	70-130		AF93648	06/14/19 11:30	06/14/19 20:01	EPA 524.2	
Bus Shed (19F1097-22)		Sample Type: Water			Sampled: 06/05/19 08:31			
Volatile Organic Compounds by EPA Method 524.2								
Benzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
Carbon tetrachloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
Chlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
1,1-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
1,2-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
1,1-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
1,2-Dichloropropane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
Ethylbenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
Methylene chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
Styrene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
Tetrachloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
Toluene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
Trichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
Trichlorofluoromethane	ND ug/L	5.0	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
Trichlorotrifluoroethane	ND ug/L	10	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
Vinyl chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
Xylenes (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District
6696 Clark Rd.
Paradise, CA 95969

Project Manager: Jacob Timm
Project: 2-Fire RemediationMonitoring
Project Number: [none]

Reported:
06/24/19 16:05

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note
Bus Shed (19F1097-22)		Sample Type: Water			Sampled: 06/05/19 08:31			
Volatile Organic Compounds by EPA Method 524.2 (cont'd)								
Surrogate: Bromofluorobenzene	110 %	70-130		AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
Surrogate: Dibromofluoromethane	104 %	70-130		AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
Surrogate: Toluene-d8	105 %	70-130		AF93648	06/14/19 11:30	06/15/19 01:05	EPA 524.2	
D.O. Foyer D.F. (19F1097-23)		Sample Type: Water			Sampled: 06/05/19 07:23			
Volatile Organic Compounds by EPA Method 524.2								
Benzene	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
Carbon tetrachloride	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
Chlorobenzene	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
1,1-Dichloroethane	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
1,2-Dichloroethane	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
1,1-Dichloroethene	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
1,2-Dichloropropane	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
Ethylbenzene	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
Methylene chloride	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
Styrene	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
Tetrachloroethene	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
Toluene	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
Trichloroethene	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
Trichlorofluoromethane	ND ug/L	5.0	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
Trichlorotrifluoroethane	ND ug/L	10	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
Vinyl chloride	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
Xylenes (total)	ND ug/L	0.50	1	AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
Surrogate: Bromofluorobenzene	112 %	70-130		AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
Surrogate: Dibromofluoromethane	109 %	70-130		AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
Surrogate: Toluene-d8	114 %	70-130		AF93766	06/18/19 12:00	06/18/19 12:49	EPA 524.2	
N. Staff Restroom D.O. (19F1097-24)		Sample Type: Water			Sampled: 06/05/19 07:41			
Volatile Organic Compounds by EPA Method 524.2								
Benzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
Carbon tetrachloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
Chlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District
6696 Clark Rd.
Paradise, CA 95969

Project Manager: Jacob Timm
Project: 2-Fire RemediationMonitoring
Project Number: [none]

Reported:
06/24/19 16:05

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note
N. Staff Restroom D.O. (19F1097-24)								
Sample Type: Water								
Sampled: 06/05/19 07:41								
Volatile Organic Compounds by EPA Method 524.2 (cont'd)								
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
1,1-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
1,2-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
1,1-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
1,2-Dichloropropane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
Ethylbenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
Methylene chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
Styrene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
Tetrachloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
Toluene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
Trichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
Trichlorofluoromethane	ND ug/L	5.0	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
Trichlorotrifluoroethane	ND ug/L	10	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
Vinyl chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
Xylenes (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
Surrogate: Bromofluorobenzene	113 %	70-130		AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
Surrogate: Dibromofluoromethane	107 %	70-130		AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
Surrogate: Toluene-d8	107 %	70-130		AF93648	06/14/19 11:30	06/15/19 02:13	EPA 524.2	
100 Wing W. D.F. PINT (19F1097-25)								
Sample Type: Water								
Sampled: 06/05/19 14:18								
Volatile Organic Compounds by EPA Method 524.2								
Benzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2	
Carbon tetrachloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2	
Chlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2	
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2	
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2	
1,1-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2	
1,2-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2	
1,1-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2	
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2	
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2	
1,2-Dichloropropane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2	
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2	
Ethylbenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District
6696 Clark Rd.
Paradise, CA 95969

Project Manager: Jacob Timm
Project: 2-Fire RemediationMonitoring
Project Number: [none]

Reported:
06/24/19 16:05

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note	
100 Wing W. D.F. PINT (19F1097-25)		Sample Type: Water			Sampled: 06/05/19 14:18				
Volatile Organic Compounds by EPA Method 524.2 (cont'd)									
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2		
Methylene chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2		
Styrene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2		
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2		
Tetrachloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2		
Toluene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2		
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2		
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2		
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2		
Trichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2		
Trichlorofluoromethane	ND ug/L	5.0	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2		
Trichlorotrifluoroethane	ND ug/L	10	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2		
Vinyl chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2		
Xylenes (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2		
Surrogate: Bromofluorobenzene	110 %	70-130		AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2		
Surrogate: Dibromofluoromethane	104 %	70-130		AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2		
Surrogate: Toluene-d8	105 %	70-130		AF93648	06/14/19 11:30	06/15/19 02:47	EPA 524.2		
Trip Blank (19F1097-26)		Sample Type: Water			Sampled: 06/05/19 00:00				
Volatile Organic Compounds by EPA Method 524.2									
Benzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2		
Carbon tetrachloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2		
Chlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2		
1,2-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2		
1,4-Dichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2		
1,1-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2		
1,2-Dichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2		
1,1-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2		
cis-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2		
trans-1,2-Dichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2		
1,2-Dichloropropane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2		
1,3-Dichloropropene (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2		
Ethylbenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2		
Methyl tert-butyl ether	ND ug/L	3.0	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2		
Methylene chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2		
Styrene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2		
1,1,2,2-Tetrachloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2		
Tetrachloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2		
Toluene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2		
1,2,4-Trichlorobenzene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2		
1,1,1-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2		
1,1,2-Trichloroethane	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2		

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
 Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District 6696 Clark Rd. Paradise, CA 95969	Project Manager: Jacob Timm Project: 2-Fire RemediationMonitoring Project Number: [none]	Reported: 06/24/19 16:05
--	--	-----------------------------

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note
Trip Blank (19F1097-26)								
				Sample Type: Water		Sampled: 06/05/19 00:00		
Volatile Organic Compounds by EPA Method 524.2 (cont'd)								
Trichloroethene	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2	
Trichlorofluoromethane	ND ug/L	5.0	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2	
Trichlorotrifluoroethane	ND ug/L	10	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2	
Vinyl chloride	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2	
Xylenes (total)	ND ug/L	0.50	1	AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2	
Surrogate: Bromofluorobenzene	106 %	70-130		AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2	
Surrogate: Dibromofluoromethane	99.4 %	70-130		AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2	
Surrogate: Toluene-d8	103 %	70-130		AF93648	06/14/19 11:30	06/15/19 03:21	EPA 524.2	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Paradise Unified School District
6696 Clark Rd.
Paradise, CA 95969

Project Manager: Jacob Timm
Project: 2-Fire RemediationMonitoring
Project Number: [none]

Reported:
06/24/19 16:05

Notes and Definitions

- QM-05 The spike recovery was outside acceptance limits for the MS and/or MSD due to matrix interference. The LCS and/or LCSD were within acceptance limits showing that the laboratory is in control and the data is acceptable.
- ND Analyte NOT DETECTED at or above the reporting limit
- dry Sample results reported on a dry weight basis
- RPD Relative Percent Difference

Chain of Custody - Work Order

Reports and Invoices delivered by email in PDF format


Lab No 19F1097 Pg 1 of 3

Corporate Laboratory
208 Mason Street, Ukiah CA 95482
707-468-0401 F) 707-468-5267
email: clientservices@alpha-labs.com

ELAP Certifications
Ukiah 1551 / Livermore 2728 / Elk Grove 292, 916-686-5190 F) 916-686-5192

Bay Area Laboratory
262 Rickenbacker Circle, Livermore CA 94551
925-828-6226 F) 925-828-6309

Central Valley Laboratory
9090 Union Park Way #113, Elk Grove CA 95624
916-686-5190 F) 916-686-5192



Report to		Invoice to (if different)		Project Information				Analysis Request		TAT		Temp upon Receipt °C			
Company:	Address:	Contact:	Project ID:	Fire Remediation Monitoring				Standard	10 days	RUSH:	Ukiah temp:	Temp upon Receipt °C			
Paradise Unified School District	6696 Clark Road Paradise, CA 95969	Attn: Jacob Timm Email address: Address: Phone/Fax: 530-872-6486	19-01224	Project No: PO Number: 19-01224				10 days	<input checked="" type="radio"/>	5 days <input type="radio"/> 48 hours <input type="radio"/> Other: _____ days <input type="radio"/>	4.5°C	Dublin temp: Elk Grove temp: 1.8			
Sample Identification		Sampling		Container			Preservative			Matrix			Total Number of Containers per Sample ID	CDPH Source Numbers:	Sample Notes or
Date	Time	40ml Vial	Sleeve	Glass	Poly	HCl	H2SO4	Other	None	Water DW	Soil	Other			
PHS Room 116	6/5/19	0932	X			X	X			X			4	524.2 DDW VOC	Date + time taken
Drinking Fountain 123 PHS		0943	X			X	X			X			4		from vials. RE 6/10/19
PHS Room 125		0948	X			X	X			X			4		No charge for trip blank.
PHS Health Office		1604	X			X	X			X			4		
200 Wing D.F. PHS		1010	X			X	X			X			4		RE 6/10/19
Café East D.F. PHS		1042	X			X	X			X			4		
PHS Kitchen		1050	X			X	X			X			4		
PHS 501		1113	X			X	X			X			4		FAXED
PHS Gym North D.F.		1138	X			X	X			X			4		
PHS Field House D.F.		1152	X			X	X			X			4		
Relinquished by		Received by		Date		Time		CDPH Write On EDT Transmission?		State System Number:		Mail Hardcopy to DDW - ?		Hardcopy to DDW attn:	
<i>[Signature]</i>		<i>[Signature]</i>		6-7-19		15:00		<input type="radio"/>				<input type="radio"/>		Misc. Supplies:	
<i>[Signature]</i>		<i>[Signature]</i>		6/7/19		1725		<input type="radio"/>				<input type="radio"/>		Mileage:	
<i>[Signature]</i>		<i>[Signature]</i>		6/6/19		1500		<input type="radio"/>				<input type="radio"/>		Misc. Supplies:	
<i>[Signature]</i>		<i>[Signature]</i>		6/10/19		18:48		<input type="radio"/>				<input type="radio"/>		Misc. Supplies:	
<i>[Signature]</i>		<i>[Signature]</i>		6-10-19		22:08		<input type="radio"/>				<input type="radio"/>		Misc. Supplies:	

Report to		Invoice to (if different)		Project Information		Analysis Request		TAT		Temp upon Receipt °C			
Company: Paradise Unified School District		Contact:		Project ID:		Standard 10-days		RUSH: 5 days		Ukiah temp: 4.5 C			
Attn: Jacob Timm		Email address:		Fire Remediation Monitoring		Other: 48 hours		Other: 5 days		Dublin temp:			
Address: 6696 Clark Road		Address:		Project No:		Other: 1 days		Lab preapproval required		Elk Grove temp: 1.8			
Phone/Fax: 696 Clark Road		Phone/Fax: 530-872-6464		PO Number: 19-01224		Sample Source Numbers:							
Email Address: jimm@pusdk12.org													
Field Sampler - Printed Name & Signature: JAKE TIMM													
Signature:													
Sample Identification		Sampling		Container		Preservative		Matrix		Total Number of Containers per Sample ID			
		Date	Time	40ml Vial	Sleeve	Other	HCl	HNO3	H2SO4	Other	Water DW	Soil	Other
PINT Café D.F.		6/5/19	1350	X			X				X		
PINT 200 West D.F.			1337	X			X				X		
PINT Health Office			1342	X			X				X		
PINT Kitchen			1357	X			X				X		
PINT 107 **			1410	X			X				X		
PINT 301			1319	X			X				X		
PINT Gym Girls L.R.			1400	X			X				X		
PINT Gym E. D.F.			1429	X			X				X		
PINT 303			1300	X			X				X		
CENT Kitchen			0841	X			X				X		
Relinquished by		Received by		Date		Time		CDPH Write On EDT Transmission?		State System Number:			
				6-7-19		15:00		Yes <input type="radio"/> No <input type="radio"/>		If "Y" please enter the Source Number(s) in the column above			
				6/7/19		1725		Yes <input type="radio"/> No <input type="radio"/>		Mail Hardcopy to DDW-?			
				6/10/19		15:00		Yes <input type="radio"/> No <input type="radio"/>		Hardcopy to LDW attn:			
				6-10-19		18:48		Yes <input type="radio"/> No <input type="radio"/>		Travel and Site Time:			
				6-10-19		22:08		Misc. Supplies:					

